

RIELLO S.p.A.

Via Risorgimento, 13
23900 Lecco (LC)
Tel. +39 0341 277111

RIELLO S.p.A.
Società con Socio unico soggetta alla
direzione e coordinamento di Riello Group SPA
Sede legale e amministrativa
37048 Legnago (VR) – Via Ing. Pilade Riello 7
Cap. soc. € 7.117.400,00 i.v.
Reg. delle Imp. di Verona N. 02641790239
C.F. e Part. IVA 02641790239

Lecco June 7, 2014

The company

Riello SpA Heating Products Direction
Via Risorgimento 13
23900 Lecco
ITALIA

declare that the boilers with brand : **Beretta**

model: **Mynute Boiler 28/60 B.A.I. ; Mynute Boiler 24/45 B.S.I. ; Mynute Boiler 28/60 B.S.I.**

are designed and produced in conformity with the Gas Appliances Directive 2009/142/CE (ex 90/396/CEE) , the Efficiency Directive 92/42/CEE , the Electro-Magnetic Compatibility Directive 2004/108/CE , the Low Voltage Directive 2006/95/CE and the following European Standards:.

- **EN 297** for type B boilers
- **EN 483** for type C boilers
- **EN 437** for test gases, test pressures and appliance categories
- **EN 625** requirements for domestic hot water operations
- **EN 60335** safety of household and similar electric appliances
- **EN 60529** protection provided by enclosures (IP code)
- **EN 61000** and **EN 55014** for Electro Magnetic Compatibility

In order to guarantee the conformity of the production with the CE certified types, the company Riello S.p.A. has put in place a production quality control based on the par. 4, Annex II of the Gas Appliances Directive 2009/142/CEE.

Kiwa Italia S.p.A. is the notified body in charge of the production surveillance.

Giuliano Conticini
Executive General Manager
Riello S.p.A.

